

Office of The Chief Medical Officer, Ghaziabad

Ref.No. DSO/IDSP/2025/9784

Dated:- 04-02-2025

WATER TEST REPORT

ADDRESS:- SETH ANANDRAM JAIPURIA SCHOOL, SEC-14, VASUNDHARA, GHAZIABAD.

PREVIOUS SAMPLE COLLECTION DATE	SAMPLE COLLECTION AREA	SAMPLE WATER WAS BEING USED	SAMPLE ID	RESULT
N/A	N/A	N/A	N/A	N/A

No of sample collected : 01

SAMPLE COLLECTION DATE	SAMPLE COLLECTION AREA	SAMPLE WATER WAS BEING USED	SAMPLE ID	RESULT
30-01-2025	RO WATER	DRINKING	4028	Satisfactory

Test Result

H₂S Water test kit : Negative (-Ve) after 24-48 hrs incubation

Comments:-

H₂S water test kit report - ve reflects that water is free from Coliforms Organism.

Recommendation:

Given water safe for drinking purpose.

➤ This Satisfactory report/result is issued with the condition that the water quality will be maintained in future otherwise, it will automatically stand cancelled on proof.



Lab Technician
IDSP Lab
Ghaziabad

(Dr R.K Gupta)
District Public Health Expert
Ghaziabad
District Surveillance Officer